

COSHH ASSESSMENT

Task/Substance Description Sempatap Adhesive Blend of aqueous acrylic polymer emulsion, resin, process oil and structuring filler with small percentages of stabilisers and thickening agent	Location/Department/Area N/A
Task Location Various location, primarily internal rooms in residential buildings.	
Substances/Processes in Use Used for the adhesion of Sempatap. Applied to walls using a brush / roller etc.	Record Number
Frequency and Duration of Exposure Dependent on size of infected area, generally short exposure duration for application.	
Control Measures in Use Ensure sufficient ventilation to the area Impermeable protective clothing Tightly fitting safety goggles Impermeable Gloves Ensure eye bath is to hand	
Risk rating (High, medium, low) LOW May cause an allergic skin reaction. Harmful if swallowed and irritating to eyes.	
Action Required No immediate action required other than ensuring all PPE is available and is utilised by all operatives engaged in the process.	Recommended Date for Implementation
Action Taken	
Name of Assessor: Steven Leach Assisted by: Site staff	Date Reviewed Jan 2020

COSHH ASSESSMENT

Further detailed information:

Wash affected parts of the body with soap and water.

Wash contaminated clothing.

Wash hands before touching food stuffs.