## COSHH ASSESSMENT

Task/Substance Description	Location/Department/Area
Biocheck Matt Emulsion Decrotative coating for combating internal problems with mould growth. Contains 2-octyl-2H-isothiazol-3-one <0.5% Diuron <0.25%	As applicable on each job
Task Location	
Various location, primarily internal rooms in residential buildings.	
Substances/Processes in Use	Record Number
Decorative coating for combating internal problems with mould growth . Applied to desired areas using a brush or roller. Apply two coats. Use as supplied	
Frequency and Duration of Exposure	
Dependent on size of infected / desired area, exposure generally for short duration during application.	
Control Measures in Use	
Ensure sufficient ventilation to the area Impermeable protective clothing Tightly fitting safety goggles Disposable P2 Respirator Impermeable Gloves Ensure eye bath is to hand	
Risk rating (High, medium, low)	
LOW	
May cause an allergic skin reaction. Signal word. Warning	
Action Required	Recommended Date for
No immediate action required other than ensuring all PPE is available and is utilised by all operatives engaged in the process	Implementation
Action Taken	
Name of Assessor: Steven Leach	Date Reviewed
Assisted by: Site staff	Jan 2020

\_\_\_\_\_

## **COSHH ASSESSMENT**

Further detailed information: Wash affected parts of the body with soap and water. Wash contaminated clothing. Wash hands before touching food stuffs.

Ref: COSHH0805 (D)